

FW-300-M



*Featuring the First Water 40™
water treatment system*

Operation Manual

First Water Systems
770-442-8257
www.firstwaterinc.com



Table of Contents

- Operation Manual*..... 1
- 1 Introduction** 1
 - 1.1 Style Conventions**..... 1
- 2 Unpacking** 2
 - 2.1 Inventory** 2
 - 2.2 Storage** 3
- 3 Startup and Operation**..... 4
 - 3.1 Water Source** 4
 - 3.2 Component Layout** 5
 - 3.4 Startup** 5
 - 3.5 Operation**..... 6
- 4 Post Operation Care** 8
 - 4.1 Flushing System**..... 8
 - 4.2 Removing Filters** 8
 - 4.3 Cleaning System**..... 8
 - 4.4 Preparing for Storage** 9
- 5 Special Procedures** 10
 - 5.1 Maintenance Intervals** 10
 - 5.2 Replacing Filters** 10
 - 5.3 Replacing UV Lamp**..... 10
 - 5.3 Replacing Quartz Sleeve** 11
 - 5.4 UV Lamp Disposal** 12
- 6 Troubleshooting**..... 13
 - 6.1 Pump will not move water**..... 13
 - 6.2 Water not flowing from Clean Water Hose** 13
 - 6.3 Water leaks from top of Canisters** 13
 - 6.4 Water leaks UV Chamber** 13

1 Introduction

The Operator's Manual has been prepared to acquaint the owner/operator with this water filtration unit, its various controls, maintenance, and safety instructions. It is valuable for the proper use of The FW-300-M and should be kept with the unit at all times.

Make sure you read and understand the content of the Operator's Manual.

First Water Systems offers water treatment experts to assist you in your water operation plans. You may contact us at any time to discuss your needs. The FW-300-M is designed to provide microbiologically safe water for human consumption from fresh water sources.

Used in conjunction with the Supply Station, Filling Station and Aqua Bags, The FW-300-M provides a complete water solution to a variety of applications.

1.1 Style Conventions

The following style conventions will be used throughout this operation manual.

Note: Notes present information that will enhance operator experience.

Warning: Warnings present information that is critical to the safety of the operator and equipment.

2 Unpacking

Upon delivery of your FW-300-M, please inspect for damage and inventory all components.

2.1 Inventory

The FW-300-M includes the following components:

- (1) Water Purification Unit
- (1) Operation Manual
- (1) Maintenance Kit (0.5oz silicone grease & 3 x Canister O-Rings)
- (1) Filter Wrench
- (1) Filter Set, installed in canisters
- (1) Filter Set, spare
- (2) UV/Quartz Sleeve sets, (1) installed/(1) spare
- (1) Source Water Hose (black)
- (1) Clean Water Hose (blue or white)
- (1) Silt Screen
- (1) Nozzle

2.2 Storage

The FW-300-M should be stored ready for deployment. The following checklist will ensure that your FW-300-M is properly stored.

- ✓ Used filters discarded
- ✓ New filters installed
- ✓ Unit clean and dry
- ✓ Canister O-Rings lubricated and in place
- ✓ UV Lamp operational
- ✓ Hoses and Accessories accounted for
- ✓ Replacement filters re-ordered

3 Startup and Operation

3.1 Water Source

The FW-300-M produces microbiologically safe water from fresh (non-saltwater) water sources. Zeonic virus media filtration utilizes adsorption properties to remove microbiology and has been proven against viruses as small as 0.019 microns. Microbiology removed includes viruses, bacteria, and cysts.

Source water can come from a variety of locations. Ideal water sources are free of sediment and turbidity and come from a relatively known environment. As the scope of an event escalates, less ideal water sources may be utilized.

Example water sources, from most ideal to least ideal:

1. Facility plumbing under boil water advisory.
2. Swimming or therapy pools.
3. Irrigation wells.
4. Shuttled water from fire trucks or tankers.
5. Rain water collected from roof runoff.
6. Surface water from retention ponds, lakes or streams.

The FW-300-M does not remove chemical contaminants from water sources. Care should be taken in using a water source from unknown locations or uncontrolled environments.

Water supplies with known chemical additives should never be used.

Water sources with high turbidity, sediment or tannin levels will cause filters to be expended more rapidly. There is no impact on the quality of clean water produced.

3.2 Component Layout

Arrange components in the following order, flowing from source water to water outlet:

- 1 Water Source
- 2 Source Water Hose with Silt Screen attached (black)
- 3 Pump
- 4 Water Purification Unit
- 5 UV Chamber
- 6 Clean Water Hose (blue or white)
- 7 Clean water distribution

3.4 Startup

- Place Source Water hose in water source
- Attach Clean Water hose to system outlet
- Plug unit into 120 volt power source
- Turn system on
- Confirm that UV Lamp is operating by inspecting UV indicator light

Power must be supplied through a Ground Fault Circuit Interrupter (GFCI) that is properly grounded.

Allow the system to run for 5 to 10 minutes prior to distributing clean water. This will ensure all carbon particles are flushed and the UV lamp has the proper contact time with water.

Water coming from the Outlet is clean, but any down stream distribution components may be compromised. Any components beyond the FW-300-M should be cleaned with a 3:1 bleach solution or other appropriate disinfectant then thoroughly rinsed before clean water is distributed.

3.5 Operation

Once water is flowing, very little maintenance is required. Someone should be present to monitor the following:

- Source water does not deplete.
- Clean water storage does not overflow.
- Water flow does not stop.
- Filters needing to be changed.

Pausing Operation

The FW-300-M may be turned off and on throughout an event. To stop the flow of water, turn any downstream valves to the off position. The pump will automatically stop. If desired, you may turn off the power to the Filtration Unit to shut off the UV Lamp.

If the system will be down for more than 4 hours, flush with clean water for 1 minute before turning off. Do not leave standing water in the unit for more than 36 hours.

Resuming Operation

After a pause in operation, the system may be restarted by turning all power back on and opening downstream valves.

Filter Maintenance During Operation

Filter life will vary greatly based on the turbidity of source water. Under optimal water conditions, a complete filter set should be replaced every 25,000 gallons. Optimal water conditions are defined as micro-biologically contaminated water sources with low levels of sediment, turbidity or tannins. Increased levels of sediment, turbidity or tannins will require more frequent changes of the sediment filter identified by observable drops in water flow. When you notice the flow rate decrease, follow the steps below to check filters:

- Disconnect all power from the unit.
- Check Silt Screen for debris.
- Replace the Sediment Filter in housing #1.
- Restart unit and observe flow rate. If flow rate has not improved, replace the Virus Media Filters.

4 Post Operation Care

4.1 Flushing System

- As soon as possible after an event, flush the system by pumping clean water for at least 5 minutes.
- Remove the Source Water Hose from the source and allow the system to pump until no water is flowing.
- Disconnect all power from the Filtration Unit.

4.2 Removing Filters

- Remove Filter Housings from the case.
- Unscrew each Canister, using the Filter Wrench where necessary.
- Retain Canister O-Ring.
- Remove and discard used Filters.
- Drain water from Canisters and dry.

4.3 Cleaning System

- Follow instructions above to flush and drain the system.
- If sediment remains in the system, replace empty Canisters and flush with clean water from a garden hose.
- Follow steps above to remove and dry filter canisters.
- Drain the UV Chamber by tilting unit slightly and allowing water to flow from the Outlet.
- Remove and drain all hoses.

- Discard used filters.
- Rinse and dry all components.
- Leaving Canisters open, allow system to air dry for at least 8 hours, longer if necessary to ensure the unit is completely dry.

4.4 Preparing for Storage

- Visually inspect the UV Bulb and Quartz Sleeve.
- Inspect and lubricate each (3) Canister O-Rings with Silicone Grease or other food grade lubricant.
- Place new filters in each Canister and screw the Canisters back on the unit.
 - Tighten Canisters hand tight only.
- Coil and store all hoses and accessories.

The FW-300-M should be stored ready for deployment. The following checklist will ensure that your FW-300-M is properly stored.

- ✓ Used filters discarded
- ✓ New filters installed
- ✓ Unit clean and dry
- ✓ Canister O-Rings lubricated and in place
- ✓ UV Lamp operational
- ✓ Hoses and Accessories accounted for
- ✓ Replacement filters re-ordered

5 Special Procedures

5.1 Maintenance Intervals

- During Operation
 - Clean Silt Screen as needed.
 - Replace Sediment Filter as needed.
 - Replace Filter Set every 25,000 gallons, or as needed based on flow rate.
- During Storage
 - Every 6 Months: Visually inspect UV Lamp operation.
 - Every 6 Months: Open Canisters to ensure unit is stored dry.

5.2 Replacing Filters

- Disconnect power from the filtration unit and remove filter housings from the case.
- Unscrew each Canister, using the Filter Wrench where necessary.
- Retain Canister O-Rings.
- Remove and discard used Filters.
- Insert new Filters into Canisters.
 - Canister 1: White, Sediment Filter, no end caps.
 - Canister 2 and 3: Silver, Zeonic Virus Media Filter, black end caps.
- Inspect and lubricate each (3) Canister O-Rings with Silicone Grease or other food grade lubricant.
- Tighten Canisters hand tight only

5.3 Replacing UV Lamp

- Disconnect power from the Filtration Unit.
- Remove UV Canister from brackets.

-
- Pull the retention pin located on the rubber UV boot.
 - Slide UV lamp from the chamber and disconnect socket.
 - Reinstall Lamp in reverse order.

Lamp and Quartz Sleeve are easily damaged. Exercise care when removing or replacing lamp.

Never look directly at an illuminated UV Lamp.

5.3 Replacing Quartz Sleeve

- Disconnect power from the Filtration Unit.
- Shut off water supply.
- Follow steps in “Replacing the UV Lamp” to remove lamp.
- Unscrew Chamber Cap from each end of Chamber.
- Remove Washer from both ends of the Quartz Sleeve.
- Carefully remove Quartz Sleeve from Chamber. NOTE: It is advisable to support the quartz sleeve on the opposite end with your finger so that it does not drop to the bottom of the chamber as it slides into the chamber.
- If removing a broken Quartz Sleeve, follow the steps below:
 - Carefully remove as much of the broken quartz sleeve as possible, from each end of the chamber.
 - To remove fragments of quartz sleeve, position the UV Chamber vertically and shake. The quartz fragments will break and drop out of the Chamber.
 - Flush water through chamber being careful to remove all quartz fragments from the interior of the chamber
- Once the quartz sleeve is removed, clean with alcohol or a mild, non-abrasive detergent. Stubborn stains usually can be removed with a diluted hydrochloric acid.
- Reassemble in reverse order. Make sure the quartz sleeve protrudes an equal distance past each threaded nipple.

- Tighten End Caps firmly by hand only, DO NOT USE HAND TOOLS. Tightening with hand tools is likely to cause Quartz Sleeve to break.
- Slowly restore water supply and check for leaks.
- If no leaks occur, reinstall lamp.

5.4 UV Lamp Disposal

Germicidal ultraviolet lamps, like standard fluorescent lamps contain small amounts of mercury. Mercury added lamps should not be placed in the trash. Dispose of properly.

For further information regarding the disposal and recycling of lamps containing mercury, along with Federal and State requirements visit <http://www.lamprecycle.org>.

6 Troubleshooting

6.1 Pump will not move water

- Check the 120 volt power source
- Check the Silt Screen for debris

6.2 Water not flowing from Clean Water Hose

- Follow troubleshooting steps for “Pump will not move water”
- Check that downstream valves are open
- Check power source to Purification Unit
- Check Silt Screen for excessive debris
- Check filters

6.3 Water leaks from top of Canisters

- Check that each Canister O-Ring is in place and lubricated
- Hand tighten Canister
- A small, dripping leak is not abnormal

6.4 Water leaks UV Chamber

- Inspect Quartz Sleeve for damage
- Inspect Quartz Sleeve O-Rings and Washers (See “Replacing Quartz Sleeve”)
- Tighten UV Canister End Cap