

COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS

CERTIFICATE Of Conformity

Certificate No: 25202502404
Applicant: GUANGDONG GOLD MEDAL CERAMICS CO.,LTD.
Address of Applicant: NO.135 (F2),SOUTH DISTRICT, "NATIONAL TORCH PLAN FOSHAN ELECTRONIC AND ELECTRICAL INDUSTRY BASE" ,BAINI TOWN,SANSHUI DISTRICT, FOSHAN CITY
Product: PORCELAIN SLAB
Type designation: See appendix to certificate of conformity
Technical data: Dry-pressed ceramic tiles for floorings and wall finishes, internal and external, with water absorption $E_b \leq 0.5\%$, Group B I a, Glazed, Flat, 320cm×160cm

The submitted samples of the above product have been tested for CE marking according to the following European Directives:

(EU)No.305/2011-the Construction Products Regulation

Standard used for showing compliance with the essential requirements in the specified directive:

Standard	Test report	Issued by	Date
EN 14411:2016	25202502404	CTC of FOSHAN CUSTOMS	Aug. 29, 2025

The referred test report shows that the product complies with standard recognized as giving presumption of compliance with the essential requirements in the specified EU Directive.

After preparation of the necessary technical documentation as well as the conformity declaration the CE marking as shown below can be affixed on the product. Other relevant Directives have to be observed.

This certificate is **NOT** valid for: *i*) uses in suspended ceilings; *ii*) uses subject to requirements against accidental fall of objects on to transit areas; *iii*) uses subject to dangerous substances regulations; *iv*) uses in vehicular circulation areas.

This document is the property of Comprehensive Technology Centre of Foshan Customs, and it is not transferable. Only the applicant may reproduce this certificate.



肖景红

XIAO JINGHONG

Director

Issue Date: Aug. 29, 2025

Expiration Date: Aug. 28, 2026

Note: This certificate is part of the full report and should be read in conjunction with it.

COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS
2/F, Building 18, Lanshi International Metal Exchange Center, Kuiqiyi Road, Chancheng District, Foshan, Guangdong, China (528000)
TEL: 86-757-83827991



COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS

APPENDIX TO Certificate of Conformity

Certificate No: 25202502404

Applicant: GUANGDONG GOLD MEDAL CERAMICS CO.,LTD.

Address of Applicant: NO.135 (F2),SOUTH DISTRICT, "NATIONAL TORCH PLAN FOSHAN
ELECTRONIC AND ELECTRICAL INDUSTRY BASE" ,BAINI TOWN,SANSHUI
DISTRICT, FOSHAN CITY

Product: PORCELAIN SLAB

Type designation: DB2M78BR-Y DB2M15BR-Y DB2M87BR-Y DB2M70BC-Y DB2M65BR-Y
DB2M64BX-Y DB2M71BC-Y DB2M85BR2-Y DB2M90CC-Y DB2M86BR1-Y
DB2M27BC-Y DB2M243CR-Y DB2M65CR-Y DB2M299BR-Y DB2M300BR-Y
DB2M301BR-Y DB2M302BX-Y DB2M48BR-Y DB2M53BC-Y DB2M53BCT-Y
DB2M48BCT-Y DB2M303BCT-Y DB2T95BC-Y DB2S55BC-Y DB2S54BC-Y
DB2S51BC-Y DB2L200CP-Y DB2M79BR1-Y DB2M16AC-Y DB2M15BP
DB2A285BL-Y DB2A285BCT-Y DB2A286AL-Y DB2A286BCT-Y DB2A287AL-Y
DB2A287BCT-Y DB2A288AL-Y DB2A288BCT-Y DB2A289AL-Y DB2A289BCT-Y
DB2A290BL-Y JNB32B038P2 JN32B126R2 JNB32B976P2 JN32B617Y2
JNB32B949P2 DB2M56BX-Y DB2M27BCT-Y DB2M12BC3-Y DB2S50BC-Y
JC32B192Y2 DB2M90BC-Y GA1632JR12A083N GA1632JR12A084N
GA1632JR12A097N GA1632CY12A096N DA1632SM12A117N DA1632SM12A118N
D1632GA2200A D1632JR2057A D1632JR2058A D1632JR2126A D1632SM2325N
DA1632GA12D032N DA1632CY12D034N DA1632GB12D033N
DA1632CY12D035N D1632DG2103N D1632DG8105N D1632DG2101N
D1632DG2104N D1632DG2100N D1632DG2102N

Note: This certificate is part of the full report and should be read in conjunction with it.

COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS
2/F, Building 18, Lanshi International Metal Exchange Center, Kuiqi Road, Chancheng District, Foshan, Guangdong, China (528000)
TEL: 86-757-83827991



中国认可
国际互认
检测
TESTING
CNAS L1978



检测报告

TEST REPORT

报告编号:
REPORT NO.: 25202502404

样品名称:
NAME OF SAMPLE: 岩板
PORCELAIN SLAB

委托单位:
APPLICANT: 广东金牌陶瓷有限公司
GUANGDONG GOLD MEDAL CERAMICS
CO.,LTD.

检测日期:
DATE OF TEST: 24/07/2025 – 22/08/2025 (dd/mm/yy)

国家建筑卫生陶瓷检测重点实验室
STATE KEY TESTING LABORATORY OF BUILDING CERAMICS AND SANITARY WARE
佛山海关综合技术中心
COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS

佛山海关综合技术中心
COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS

检测报告
TEST REPORT

报告编号: 25202502404

共 6 页 第 2 页

Report No:

Page 2 of 6

样品名称 Name of sample	岩板 PORCELAIN SLAB	名义尺寸 Nominal size (N)	320cm×160cm
表面特性 Nature of the surface	有釉 Glazed (GL)	工作尺寸 Work size	3200mm×1600mm×12.0mm
类别 Group	B I a	预期用途 Intended use	室内外墙地砖 Floorings and wall finishes, Interior and exterior
样品标记 Mark of samples	DB2M65BR-Y	样品数量 Quantity of samples	30 片 30 Pieces
委托单位 Applicant	广东金牌陶瓷有限公司 GUANGDONG GOLD MEDAL CERAMICS CO.,LTD.	委托单位地址 Address of applicant	佛山市三水区白坭镇“国家火炬 计划佛山电子电器产业基地”南 区 135 号 (F2) NO.135 (F2),SOUTH DISTRICT, "NATIONAL TORCH PLAN FOSHAN ELECTRONIC AND ELECTRICAL INDUSTRY BASE",BAINI TOWN,SANSHUI DISTRICT, FOSHAN CITY
委托单位电话 Telephone of applicant	0757-82523883	委托单位传真 Fax of Applicant	—
样品来源 Source of Samples	委托单位自送样品 Samples selected by applicant	接样日期 Received on	23/07/2025
检测依据 Test Standard	EN 14411:2016 Ceramic tiles - Definition, classification, characteristics, assessment and verification of constancy of performance and marking		
检测结论 Conclusion of Test	样品经检测,所检测项目的检测结果符合 EN 14411:2016 标准中附录 G 的规定。 The results conform to the requirement of Annex G of standard EN 14411:2016 with respect to the test items.		
检测单位盖章 Stamp of Test Unit	 日期: 29/08/2025 Date:	检测单位联系方式 Address of Test Unit	地址: 广东省佛山市禅城区魁奇一路澜石(国际)金属交易中心十八座二楼 Address: 2/F, Building 18, Lanshi International Metal Exchange Center, Kuiqi Road, Chancheng District, Foshan, Guangdong, China (528000) 电话 (Tel): 86-757-83827991 邮箱 (E-mail): fsiqtc@163.com
声明 Notes	1,我们已尽所知所能实施上述检测,不能因签发本报告而免除有关各方根据合同和法律所承担的责任和义务; All tests are carried out conscientiously to the best of our knowledge and ability. This report does not in any respect absolve the other related parties from his contractual and legal obligations. 2,未经本实验室书面许可,不得部分复制本报告; This report shall not be reproduced, except in full, without the prior written approval from the issuing laboratory. 3,本报告仅是样品的检测结果。 The results in this report apply to the samples only. 4,本报告所述的样品信息为委托单位自行声明,实验室不负责其真实性。 The product information is declared by applicant, and laboratory is not responsible for the authenticity.		

检测负责人

Tested by

刘仁清

审核

Inspected by

李琪

批准

Approved by

肖景仁

佛山海关综合技术中心
COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS

检测报告
TEST REPORT

报告编号: 25202502404
Report No:

共 6 页 第 3 页
Page 3 of 6

委托单位声明
Remark of applicant

产品系列名称: 岩板

Product family: PORCELAIN SLAB

表面特性: 平面, 有釉

Nature of the surface: Flat, Glazed (GL)

产品类别 Group: B I a

名义尺寸 Nominal size (N): 320cm×160cm

本系列所包含的产品型号 Items in the family:

DB2M78BR-Y DB2M15BR-Y DB2M87BR-Y DB2M70BC-Y DB2M65BR-Y DB2M64BX-Y DB2M71BC-Y
DB2M85BR2-Y DB2M90CC-Y DB2M86BR1-Y DB2M27BC-Y DB2M243CR-Y DB2M65CR-Y DB2M299BR-Y
DB2M300BR-Y DB2M301BR-Y DB2M302BX-Y DB2M48BR-Y DB2M53BC-Y DB2M53BCT-Y DB2M48BCT-Y
DB2M303BCT-Y DB2T95BC-Y DB2S55BC-Y DB2S54BC-Y DB2S51BC-Y DB2L200CP-Y DB2M79BR1-Y
DB2M16AC-Y DB2M15BP DB2A285BL-Y DB2A285BCT-Y DB2A286AL-Y DB2A286BCT-Y DB2A287AL-Y
DB2A287BCT-Y DB2A288AL-Y DB2A288BCT-Y DB2A289AL-Y DB2A289BCT-Y DB2A290BL-Y JNB32B038P2
JN32B126R2 JNB32B976P2 JN32B617Y2 JNB32B949P2 DB2M56BX-Y DB2M27BCT-Y DB2M12BC3-Y
DB2S50BC-Y JC32B192Y2 DB2M90BC-Y GA1632JR12A083N GA1632JR12A084N GA1632JR12A097N
GA1632CY12A096N DA1632SM12A117N DA1632SM12A118N D1632GA2200A D1632JR2057A D1632JR2058A
D1632JR2126A D1632SM2325N DA1632GA12D032N DA1632CY12D034N DA1632GB12D033N
DA1632CY12D035N D1632DG2103N D1632DG8105N D1632DG2101N D1632DG2104N D1632DG2100N
D1632DG2102N

本系列所包含产品型号的吸水率,规格,使用的材料,采用的成型方法以及表面特征是一致的, 区别在于外观设计。
All items in the family are same in water absorption, dimensions and thickness, material, method of manufacture
and natural of surface except for the design of appearance.

样品照片
Photo of Samples



佛山海关综合技术中心

COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS

检测报告

TEST REPORT

报告编号: 25202502404

Report No:

共 6 页 第 4 页

Page 4 of 6

EN 14411:2016 Ceramic tiles - Definition, classification, characteristics, assessment and verification of constancy of performance and marking Annex G Requirements for dry-pressed ceramic tiles with low water absorption of Group B I a ($E_b \leq 0,5\%$)					
条款 Clause	性能 Properties	检测方法 Test Method	要求 Requirements	检测结果 Results	判定 Verdicts
A	尺寸和表面质量 Dimensions and surface quality				
A.1	长度 Length 每块砖的平均尺寸相对于工作尺寸的允许偏差 The deviation, of the average size for each tile from the work size	EN ISO 10545-2:2018	$\pm 0.6\%$	0	P
	$\pm 2.0\text{mm}$		0~+0.2mm	P	
	宽度 Width 每块砖的平均尺寸相对于工作尺寸的允许偏差 The deviation, of the average size for each tile from the work size	EN ISO 10545-2:2018	$\pm 0.6\%$	+0.02%~+0.03%	P
	$\pm 2.0\text{mm}$		+0.2mm~+0.4mm	P	
A.2	厚度 Thickness 每块砖厚度的平均值相对于工作尺寸的最大允许偏差 The permissible deviation, of the average thickness of each tile from the work size thickness	EN ISO 10545-2:2018	$\pm 5\%$	+0.2%~+1.3%	P
			$\pm 0.5\text{mm}$	0~+0.2mm	P
B	物理性能 Physical properties				
B.1	吸水率 质量分数 Water absorption Percent mass fraction	EN ISO 10545-3:2018	$E_b \leq 0.5\%$	0.05%	P
			单个值不大于 0.6% Individual maximum 0.6%	0.04%~0.06%	P
B.2	破坏强度/N Breaking strength, in N	EN ISO 10545-4:2019	≥ 1300	4950	P
B.3	断裂模数/(N/mm ²) Modulus of rupture, in N/mm ² 不适用于破坏强度> 3000N 的陶瓷砖 Not applicable to tiles with breaking strength > 3000N	EN ISO 10545-4:2019	平均值 ≥ 35 Minimum 35	52.0	N/A
			单个值 ≥ 32 Individual minimum 32	49.7~53.9	N/A
B.4	耐磨性 Abrasion resistance 用于地面的有釉砖的表面耐磨性 Resistance to surface abrasion of glazed tiles intended for use on floors	EN ISO 10545-7:1998 /AC:1999	报告耐磨级别 Report abrasion class	4 级 Class 4	—
			报告耐磨转数 Report cycles passed	6000	—
B.6	抗热震性 Thermal shock resistance	EN ISO 10545-9:2013	应通过此项测试 Pass	样品经试验, 无炸裂或裂纹 Fully resistance	P
B.7	抗釉裂性: 有釉砖 Crazing resistance: glazed tiles	EN ISO 10545-11:1996	应通过此项测试 Pass	样品经试验, 无裂纹或剥落 Fully resistance	P
B.8	抗冻性 Frost resistance	EN ISO 10545-12:1997	应通过此项测试 Pass	所有样品无裂纹或破损 Fully resistance	P

佛山海关综合技术中心
COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS

检测报告
TEST REPORT

报告编号: 25202502404
Report No:

共 6 页 第 5 页
Page 5 of 6

EN 14411:2016 Ceramic tiles - Definition, classification, characteristics, assessment and verification of constancy of performance and marking Annex G Requirements for dry-pressed ceramic tiles with low water absorption of Group B I a ($E_b \leq 0,5\%$)					
条款 Clause	性能 Properties	检测方法 Test Method	要求 Requirements	检测结果 Results	判定 Verdicts
B.9	防滑性能 Slipperiness				
	倾斜平台法, 穿鞋油法 Shod ramp test	DIN EN 16165: 2023 附录 B Annex B	报告检测结果 Declared value	修正后的平均临界角 $\alpha_{shod}: < 6^\circ$ Ramp test value $\alpha_{shod}: < 6^\circ$ 防滑等级: — Slip resistance class: —	—
	摆锤法, PTV 96 Pendulum friction test, PTV 96	EN 16165: 2021 附录 C Annex C	报告检测结果 Declared value	干法 Dry: 56 湿法 Wet: 12	—
B.14	防火性能 Reaction to fire	无需测试 CWT	A1 or A1 _{FL} 级 Class A1 or A1 _{FL}	墙砖: A1 级 地砖: A1 _n 级 Used for walls: Class A1 Used for floorings: Class A1 _n	P
C	化学性能 Chemical properties				
C.1	耐污染性 Resistance to staining				
	a) 轻油中的铬绿 a) Green staining agent in light oil	EN ISO 10545-14:2015	不低于 3 级 Minimum Class 3	5 级 Class 5	P
	b) 轻油中的红色污染物 b) Red staining agent in light oil	EN ISO 10545-14:2015	不低于 3 级 Minimum Class 3	5 级 Class 5	P
	c) 13g/L 碘酒液 c) Iodine, 13g/L solution in alcohol	EN ISO 10545-14:2015	不低于 3 级 Minimum Class 3	5 级 Class 5	P
	d) 橄榄油 d) Olive oil	EN ISO 10545-14:2015	不低于 3 级 Minimum Class 3	5 级 Class 5	P
C.2	耐化学腐蚀性 Resistance to chemicals				
	耐家庭化学试剂和游泳池盐类 Resistance to household chemicals and swimming pool salts				
	家庭化学试剂: 氯化铵溶液, 100g/L a) Household chemicals: Ammonium chloride, 100g/L	EN ISO 10545-13:2016	不低于 B 级 Minimum class B	A	P
	b) 游泳池盐类: 次氯酸钠溶液, 20mg/L b) Swimming pool salts: Sodium hypochlorite solution, 20mg/L	EN ISO 10545-13:2016	不低于 B 级 Minimum class B	A	P
	耐低浓度酸和碱 Resistance to low concentrations of acids and alkalis				
	a) 3%盐酸溶液(v/v) a) Hydrochloric acid solution, 3% (v/v)	EN ISO 10545-13:2016	报告检测结果 Declared value	LA	—
	b) 柠檬酸溶液, 100g/L b) Citric acid solution, 100g/L	EN ISO 10545-13:2016	报告检测结果 Declared value	LA	—
	c) 氢氧化钾溶液, 30g/L c) Potassium hydroxide, 30g/L	EN ISO 10545-13:2016	报告检测结果 Declared value	LA	—

佛山海关综合技术中心
COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS

检测报告
TEST REPORT

报告编号: 25202502404
Report No:

共 6 页 第 6 页
Page 6 of 6

EN 14411:2016 Ceramic tiles - Definition, classification, characteristics, assessment and verification of constancy of performance and marking Annex G Requirements for dry-pressed ceramic tiles with low water absorption of Group B I a ($E_b \leq 0,5\%$)					
条款 Clause	性能 Properties	检测方法 Test Method	要求 Requirements	检测结果 Results	判定 Verdicts
C.2	耐高浓度酸和碱 Resistance to high concentrations of acids and alkalis				
	a) 18%盐酸溶液(v/v) a) Hydrochloric acid solution, 18% (v/v)	EN ISO 10545-13:2016	报告检测结果 Declared value	HA	—
	b) 5 %乳酸溶液(v/v) b) Lactic acid, 5 % (v/v)	EN ISO 10545-13:2016	报告检测结果 Declared value	HA	—
	c) 氢氧化钾溶液, 100g/L c) Potassium hydroxide, 100g/L	EN ISO 10545-13:2016	报告检测结果 Declared value	HA	—

用语说明 Possible test case verdicts

1. P(ass): 合格 *Test item does meet the requirement.*
2. F(ail): 不合格 *Test item does not meet the requirement.*
3. —: 未进行判定 *Verdict was not carried out.*
4. N/A: 不适用 *Test case does not apply to the test item.*

*** **

报告结束 End of Test Report